

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/School/619

Dated: 06/09/2023

FIRE SAFETY CERTIFICATE

Certified that the building Dwarka International Shool Located at Sector-12, Dwarka, New Delhi - 110075, comprised of Basement+ Ground + 3 Upper floors was issued FSC vide letter No. F6/DFS/MS/School/2020/SZ/285, dated-14/08/2020. The premises was re inspected by the officer concerned of this department on 28/08/2023 in the presence of Sh. Virender Chaudhary (Chairman) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 - 362 dated 17/01/2005 and that the premises is fit for occupancy class B "Educational building" with effect from 06/09/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/09/2023 at New Delhi by.

(Arul Garg)
Director
Delhi Fire Service.

Copy to:

1. The Principal, Dwarka International Shool Located at Sector-12, Dwarka, New Delhi - 110075.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. New Block in school premises is under construction. It shall not be occupied without getting FSC.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate six months prior to its expiry. www.dfs.delhigovt.nic.in
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.



DWARKA INTERNATIONAL SCHOOL
CHAIRMAN